

# Microbiological Analysis Results for the Magnetic Treatment of Legionella Bacteria In a Berlin Clinical Building Warm Water Supply

Test No.	Elapsed Time (days)	Colony Forming Units (cfu/ml)
1	0	127
2	10	36
3	21	244 ++
4	33	12
5	49	Nil

++ - The increased cfu/ml value in test 3 was caused by the magnetic treatment removing the existing lime scale.

## Legionella Count (cfu/ml) With MFC's Installed

